

FIGURES





Fig. 1


1000 GAL. WATER STORAGE TANK



SL-1 TURBINE GENERATOR VIEWED FROM PURIFICATION PANEL

Fig. 2

Fig. 2



1000 GAL. WATER STORAGE TANK

SHIELD BLOCKS


SPACE HEAT EXCHANGER

MOTOR CONTROL PANEL

SL-1 OPERATING FLOOR TO RIGHT OF PERSONNEL ENTRANCE

Fig. 3


Fig. 3



SL-1 OPERATING FLOOR TO LEFT OF PERSONNEL ENTRANCE


Fig. 4

FIG. 4




SL-1 REACTOR PERSPECTIVE

Fig.5



OVERHEAD VIEW OF SL-1 CORE ON APRIL, 1959
Fig. 6

Fig. 6



SL-1 REACTOR VERTICAL CROSS SECTION

Fig. 7

KEY:




- NON REMOVABLE CORE STRUCTURE



- LOWER SPRAY RING AND PIPING



- REMOVABLE CORE COMPONENTS AND INSTRUMENT





CONTROL RODS AND CADMIUM SHIMS


**REACTOR VESSEL HEAD PHANTOM VIEW
WITH PORTS UNCOVERED BY EXCURSION
SHOWN OPEN**

**SL-1 CORE
AS OF JAN. 3, 1961**

Fig. 8






BORON STRIP FULL LENGTH OF SIDE PLATE



reprinted from ANL-5744 (Fig.9)


SL-1 FUEL ASSEMBLY

Fig. 9



reprinted from ANL-5744 (Fig.10)


SL-1 CRUCIFORM CONTROL ROD
Fig.10



- No. 1-4-7-10
- No. 2-5-8-11 BRAZED
- No. 3-6-9-12 PEENED

NOTE:

- 1 - CENTER DRILL 0.125" RADIUS
- 2 - DRILL 0.067 - 0.068 DIA. - 1.80" DEEP FROM SIDE PLATE SURFACE




SECTION A - A

THERMOCOUPLE LOCATION
SL-1 INSTRUMENTED FUEL ASSEMBLY


Fig. 11

Fig. 11




SL-1 CORE I INSTRUMENTED
FUEL ASSEMBLY
Fig. 12

Fig. 12




INSTRUMENTED FUEL ASSEMBLY PLATE TEMPERATURES
 REACTOR AT 3MW

Fig. 13




*THE EFFECT OF REACTOR POWER
ON SL-1 MAXIMUM FUEL PLATE
TEMPERATURE*

Fig. 14



SL-1 FUEL ASSEMBLY No. 19 -
VERTICAL VIEW - AUG. 1960
Fig. 15

Fig. 15



B-AI. SIDE PLATE


0.17 INCHES GAP

SIDE 4


SL-1 FUEL ASSEMBLY No. 19 - SIDE VIEW - AUG. 1960
Fig. 16

Fig. 16

UNIRRADIATED BORON STRIP



STRIP No. 42



STRIP No. 35




COMPARISON OF REMAINING PIECES OF ALUMINUM-BORON STRIPS WITH UNIRRADIATED STRIP
Fig. 17

Fig. 17




DEBRIS RECOVERED FROM BOTTOM OF SL-1 REACTOR VESSEL
Fig. 18

Fig 18




**SILVER-INDIUM-CADMIUM CORROSION TEST
ASSEMBLY FOR SL-1**

Fig. 20



KEY:

FULL STRIP OF BORON - DASH LINE
 HALF STRIP OF BORON - SOLID LINE
 D - DUMMY ELEMENT
 S - SOURCE



The position of the full and dotted lines indicate the orientation of the assembly and the position of the boron within a cell of four assemblies.

The direction of the side plates of the dummy elements are shown by an arrow.

SL-1 LOADING FOR 40 ELEMENT CORE






Fig.22



CHANGE IN THERMAL UTILIZATION FOR VARIOUS TIME DEPENDENT BORON SELF SHIELDING FACTORS (RELATIVE TO URANIUM)

Fig. 23



CRITICAL ROD BANK POSITION FOR VARIOUS TIME INDEPENDENT SELF SHIELDING FACTORS (RELATIVE TO URANIUM) (ONE DIMENSIONAL WINDOW SHADE TECHNIQUE)

Fig. 24

Fig. 24






Fig. 25





ESTIMATE OF ROD WORTH vs. POSITION FOR SL-1
 (TAKEN FROM CEND 1005; CALIBRATION
 CURVES CORRECTED FOR EFFECTIVE
 β OF 0.007)

Fig. 2i




Fig. 28
 SL-1 ROD BANK POSITION VS.
 WATER TEMPERATURE ~ 200 MW





Fig. 29

EXPERIMENTAL CRITICAL ROD BANK POSITION VS. STEAM FLOW, NO XENON PRESENT


Fig. 29




SL-1 ROD BANK POSITION VS. CORE LIFE
(PHYSICS TEST DATA)

Fig. 30

Fig. 30




COLD AND HOT OPERATING (18000 lbs/hr STEAM FLOW AND EQUILIBRIUM XENON) CRITICAL ROD BANK POSITIONS IN SL-1 vs. CALENDAR TIME FOR 1959
 Fig. 31




COLD AND HOT OPERATING (8000 lbs/hr STEAM FLOW AND EQUILIBRIUM XENON) CRITICAL ROD BANK POSITIONS IN SL-1 vs. CALENDAR TIME FOR 1960
 Fig. 32

CHT OPERATING ROOMS: STEEL FLOW AND BENCH POSITIONING IN ST-1 VS. MERMARIT DAYS OF OPERATION




NO. OBSERV. = 1
 MINIMUM VALUE = 130000
 MAXIMUM VALUE = 140000
 (MINIMUM VALUE) = 130000



ESTIMATED SHUTDOWN MARGIN AT 83°F
FOR SL-1 BASED ON CALIBRATIONS OF
RODS 5&9, GOLD, NO XENON

Fig 34

Fig 34




ESTIMATED SHUTDOWN MARGIN FOR SL-1
 BASED ON ARGONNE ROD CALIBRATIONS
 COLD, NO XENON


Fig. 35

Fig. 35

ROD DRIVE HOUSING



SI-1 CONTROL ROD DRIVE MECHANISM Fig. 36




- | | | | | |
|----------------------------|--------------------|------------------|-------------------------|------------------------|
| 1. Electrical connection | 41. Bearing cap | 45. Set screws | 49. Drive shaft | 53. Socket head screws |
| 2. Set Screws | 42. Spline | 46. Cam clutch | 50. Bearing | 54. Socket head screws |
| 39. Change gear | 43. Bearing | 47. Hole | 51. Negator spring drum | 55. Negator spring |
| 40. Socket head cap screws | 44. Shaft assembly | 48. Clutch cover | 52. Magnetic clutch | 56. Negator spring |

SL-1 CONTROL ROD DRIVE CLUTCH ASSEMBLY
Fig. 37

Fig. 37


CONTROL ROD DRIVE

Reprinted from NUCLEAR POWER
PLANT OPERATORS MANUAL,
CHAPTER II-(Fig. 4)




- ① SEAL COOLING WATER INLET
- ② SEAL COOLING WATER OUTLET
- ③ TE. ROD STOP
- ④ FRICTION SHAFT EXTENSION
- ⑤ THIMBLE
- ⑥ MAT SLEATED SET 1 REED CENTER PIN SET 1 REED ALSO CODE 2PFR22-028
- ⑦ STOP WASHER
- ⑧ SOCKET AIR CAPSCREW
- ⑨ 3/8" DIA. 304L IN. LG. 17 REED
- ⑩ SUPPORT BRACKET
- ⑪ RETAINING RING 1 REED
- ⑫ BALL BEARING 1 REED
- ⑬ BALL BEARING 2 REED
- ⑭ BALL BEARING 3 REED
- ⑮ BALL BEARING 4 REED
- ⑯ BALL BEARING 5 REED
- ⑰ BALL BEARING 6 REED
- ⑱ BALL BEARING 7 REED
- ⑲ BALL BEARING 8 REED
- ⑳ BALL BEARING 9 REED
- ㉑ BALL BEARING 10 REED
- ㉒ BALL BEARING 11 REED
- ㉓ BALL BEARING 12 REED
- ㉔ BALL BEARING 13 REED
- ㉕ BALL BEARING 14 REED
- ㉖ BALL BEARING 15 REED
- ㉗ BALL BEARING 16 REED
- ㉘ BALL BEARING 17 REED
- ㉙ BALL BEARING 18 REED
- ㉚ BALL BEARING 19 REED
- ㉛ BALL BEARING 20 REED
- ㉜ BALL BEARING 21 REED
- ㉝ BALL BEARING 22 REED
- ㉞ BALL BEARING 23 REED
- ㉟ BALL BEARING 24 REED
- ㊱ BALL BEARING 25 REED
- ㊲ BALL BEARING 26 REED
- ㊳ BALL BEARING 27 REED
- ㊴ BALL BEARING 28 REED
- ㊵ BALL BEARING 29 REED
- ㊶ BALL BEARING 30 REED
- ㊷ BALL BEARING 31 REED
- ㊸ BALL BEARING 32 REED
- ㊹ BALL BEARING 33 REED
- ㊺ BALL BEARING 34 REED
- ㊻ BALL BEARING 35 REED

Fig.38




① CONTROL ROD POSITION WITH SCRAM STOP WASHER AND NUT REMOVED.
 ② CONTROL ROD POSITION FOR INSTALLATION OF SCRAM STOP WASHER AND NUT.
 ③ CONTROL ROD ZERO POSITION
SL-1 CONTROL ROD CADMIUM OVERLAP OF ACTIVE CORE
Fig. 39



SPECIAL TOOL
CRT *1

*Reprinted from NUCLEAR POWER PLANT
OPERATOR'S COURSE, CHAPTER II (Fig.5)
Fig. 40*




Reprinted from NUCLEAR POWER PLANT
OPERATOR'S COURSE, CHAPTER II (Fig. 6)
Fig. 41

Fig. 41




SPECIAL TOOL
CRT #2
CLOSE - UP

*Reprinted from NUCLEAR POWER PLANT
OPERATOR'S COURSE, CHAPTER II (Fig. 7)
Fig. 42*



SECTION "A-A"



UPPER HOUSING

BACK-UP ROLLER

FLOATING RING SEAL

COUPLING

CONNECTOR BOLT

RACK ASS'Y

HARD STOP


PINION
PINION HOUSING

VESSEL HEAD NOZZLE

HOUSING EXTENSION SLEEVE

CONTROL ROD EXTENSION ASS'Y

CONTROL ROD



PL CONTROL ROD DRIVE MECHANISM, DRIVE PACKAGE
Fig. 44

Fig. 44






Fig. 45




FREQUENCY OF BOILING NOISE
 vs. POWER LEVEL - SL-1

Fig. 46



TYPICAL DATA
 BOILING NOISE FROM 1 TO 4.7 MW
 CD SHIMS IN T-ROD SLOTS -SL-1


Fig. 47



SL-1 HEAD CLOSURE GASKET EXTENDING
OUTSIDE OF GROOVE, AS SEEN WHEN
REMOVING THE HEAD ON APRIL 1959


Fig. 48

Fig. 48




SL-1 FUEL ASSEMBLY COFFIN
Fig. 49

reprinted from ANL-6084 (Fig. 21)




INTERIOR VIEW OF SL-1 BUILDING
AFTER EXCURSION Fig. 50

Fig. 50



VIEW OF SL-1 HEAD AFTER EXCURSION
Fig. 51


Fig. 51



VIEW OF CEILING ABOVE REACTOR
SHOWING DAMAGE FROM MISSILES

Fig. 52

Fig. 52



EQUIPMENT FOR REMOTE PHOTOGRAPHIC OBSERVATIONS
Fig. 53

Fig. 53

REACTOR HEAD AFTER
EXCURSION Fig. 54






Fig. 54




POSITION OF CREW AND CONDITION
OF REACTOR HEAD JUST PRIOR TO
INCIDENT

Fig. 55



POSITION OF CREW AND CONDITION OF
REACTOR HEAD JUST AFTER INCIDENT
Fig. 56



TYPICAL FRAMES FROM MOTION PICTURE OBSERVATION
THROUGH HEAD PORTS ON FEB. 22, 1961

Fig. 57








Fig. 58

*TYPICAL PICTURES FROM MINIATURE CAMERA ENTRY
ON MAY 11, 1961*

Fig. 58






PHOTO-ANALYSIS OF VESSEL INTERIOR.
(REPRINTED FROM USNPIC REPORT N-PZII P.6)
Fig. 59



BEFORE USE - DARK SPOTS
ARE CHEMICAL CRYSTALS


AFTER 2 MIN. IN WATER -
FIBER COLORED BY CHEMICAL

CHEMICAL WATER PROBE
(SECTION) Fig. 60




TOP END OF CHEMICAL WATER PROBE

MINIATURE CAMERA PHOTOGRAPH
THROUGH PORT No. 8 *Fig. 61*



*REMOTELY CONTROLLED SHIELDED
MINIATURE CAMERA ASSEMBLY.
Fig. 62*

Fig. 62



**WATER PROBE ENTRY
 REFERENCE DIMENSIONS
 Fig. 63**






Fig. 64

Fig. 64



GAMMA RADIATION - PINHOLE CAMERA
PICTURE LOOKING AT EMERGENCY
PERSONNEL DOOR FROM GROUND LEVEL

Fig. 65




GAMMA RADIATION-PINHOLE CAMERA
PICTURE LOOKING AT CARGO DOOR
FROM GROUND LEVEL

Fig. 66




GAMMA RADIATION-PINHOLE CAMERA
PICTURE LOOKING AT CARGO DOOR
FROM 18 FT. ABOVE GROUND LEVEL

Fig. 67



TRIANGULATION OF THREE PINHOLE CAMERA PICTURES
SHOWING RADIATION "HOT SPOTS"




SURVEYED -
JAN. 10, 1961

RADIATION SURVEY OF SL-1 MILITARY TRAINING BUILDING Fig. 69


SURVEYED - JAN. 11, 1961

SUPPORT FACILITY



RADIATION SURVEY OF FIRST FLOOR -
SL-1 ADMINISTRATION BUILDING

Fig. 70




SURVEYED JAN 11, 1961

RADIATION SURVEY OF SECOND FLOOR-
SL-1 ADMINISTRATION BUILDING


Fig. 71

SURVEYED JAN. 11, 1961



RADIATION SURVEY OF
SL-1 SUPPORT FACILITIES Fig. 72
BUILDING

SURVEYED - JAN. 11, 1961




- | | |
|----------------------------------|------------------------------------------------------------|
| 1. TURBINE-GENERATOR | 11. WASTE STORAGE TANKS |
| 2. HEAT EXCHANGER | 12. FEED WATER LINE FILTER |
| 3. WATER STORAGE TANK (OVERHEAD) | 13. PURIFICATION SYSTEM AREA |
| 4. MOTOR CONTROL BOARD | 14. CONTAMINATED WATER STORAGE TANK |
| 5. COVERED STAIRWAY | 15. BORON STORAGE TANK |
| 6. CONDENSATE CIRCULATING PUMP | 16. COVERED EMERGENCY STAIRWAY |
| 7. HOTWELL (OVERHEAD) | 17. CONTROL ROD DRIVE MOTORS |
| 8. FEED WATER PUMPS | 18. CONCRETE SHIELD |
| 9. FUEL STORAGE WELLS | 19. SUPPORT FACILITIES BUILDING
(CONTROL ROOM LOCATION) |
| 10. EQUIPMENT DOORS | |

RADIATION SURVEY OF
SL-1 OPERATING FLOOR


Fig. 73

OFFICIAL USE ONLY



SL-1 SITE RADIATION SURVEY
SURVEYED—JAN. 13, 1961


OFFICIAL USE ONLY



SL-1 SITE RADIATION SURVEY
SURVEYED JAN 18, 1961

OFFICIAL USE ONLY

Fig. 75



SEE PAGE
PIT



ALL READINGS IN MR/HR
INSTRUMENT - HR JUNO 100 HP 1887



SL-1 SITE ISODOSE PLOT


SURVEYED 6 MARCH 1961

Fig. 76




SL-1 SITE
SOIL SAMPLE LOCATIONS

Fig. 77




SL-1 SITE
NUCLEAR DOSIMETERS & AIR SAMPLERS

Fig. 78




A-R-E-A MONITOR-WEST WALL-OPERATING CORRIDOR
Fig. 79




CLOCK TIME (PM-JAN.3.1961)

A-R-E-A MONITOR-SOUTH HOT CELL FILTER
Fig. 80




CLOCK TIME (PM-JAN.3, 1961) A-R-E-A MONITOR-NORTH HOT CELL FILTER Fig.81



CLOCK TIME (PM - JAN. 3, 1961)

AREA MONITOR-
DECONTAMINATION ROOM


Fig. 82



CLOCK TIME (PM-JAN. 3, 1961)


AREA MONITOR-CHEMISTRY LABORATORY

Fig. 83




CLOCK TIME (PM-JAN.3,1961)

A-R-E-A MONITOR-SERVICE AREA *Fig. 84*




A-R-E-A STACK MONITOR

Fig. 85




A.R.E.A. STACK MONITOR CHART
Fig. 86

Fig. 86




A-R-E-A CONSTANT AIR MONITOR CHART
Fig. 87

Fig. 87




**ACCUMULATION OF FISSION PRODUCTS
ON A-R-E-A CAM FILTER** **Fig. 88**

Fig. 88



COMPARISON OF DECAY CURVES OF A.R.E.A MONITORS STARTING 60 SECONDS AFTER EXCURSION Fig. 89



COMPARISON OF DECAY CURVES OF A.R.E.A.
 MONITORS STARTING 30 SECONDS AFTER
 EXCURSION
 Fig. 90






Fig. 91
 A-REA MONITOR READINGS AND THEORETICAL Y-RAY CURVES FROM FISSION PRODUCTS FORMED BY A 400 Mw/sec. EXCURSION 11 DAYS AFTER STEADY OPERATION AT 2.25 Mw



A.R.E.A. MONITOR READINGS AND THEORETICAL γ -RAY CURVES FROM FISSION PRODUCTS FORMED BY A 200 Mw/sec. EXCURSION 11 DAYS AFTER STEADY OPERATION AT 2.25 MW

Fig. 92


$$\alpha/\sqrt[3]{x}, \text{SEC}^{-1} \text{cm}^{-\frac{1}{3}}$$



EXCURSION PRESSURES FOR 3 SPERT CORES


Fig. 93

$$\frac{\alpha}{\sqrt{x}}, \text{ SEC}^{-1} \text{ CM}^{-\frac{1}{3}}$$



EXCURSION PRESSURES FOR SPERT CORE 17/28


Fig. 94



$$\alpha = \frac{1}{\tau} = \frac{1}{\text{MIN. PERIOD}}, \text{SEC.}^{-1}$$


MAXIMUM EXCURSION PRESSURE IN SL-1 AS
 INFERRED FROM SPERT CORRELATION, NOT
 VALID WHEN PLATES MELT

Fig. 95



$$\alpha = \frac{1}{\tau}, \text{ SEC}^{-1}$$


ESTIMATED MAXIMUM FUEL PLATE TEMPERATURES FOR SL-1 Fig. 97



RATIO OF TEMP. RISE OF FUEL PLATE CENTER TO TEMP. RISE OF FUEL PLATE SURFACE, FOR EXPONENTIAL POWER INCREASE

Fig. 98


Fig. 98



PERIOD OF EXPONENTIAL POWER RISE, τ , m-sec.


TEMP. AT CENTER OF FUEL PLATE WHEN SURFACE TEMP. REACHES 121°C

Fig. 99



MOCK-UP TEST FOR RATE OF MANUAL
CONTROL ROD WITHDRAWAL

Fig. 100




*POSITION OF MECHANIC PREPARING
TO LIFT SL-1 CONTROL ROD*




*POSITION OF MECHANIC
AFTER LIFTING CONTROL
ROD 30 INCHES*

CONTROL ROD LIFTING TESTS ON MOCKUP

Fig. 101





LEGEND

SYMBOLS



- Areas Obscured by #9 Control Rod



- Area Obscured by Upper Spray Ring



- Fuel Element Boxes and Spare Boxes



- Possible Additional Boxes

ANNOTATIONS

- A - Upper Spray Ring
- B - Lower Spray Ring
- B' - Lower Spray Ring Bracket
- C - Filler Pipe - Lower Spray Ring
- D - Spare 1" Pipe
- E - Purification Water Inlet
- F - #5 Rod Extension
- G - #7 Rod Extension
- H - Probable Cross-Stanchion from #9 Shroud Area
- J - Possible Cross-Stanchion from #9 Shroud Area
- K - Shrouds
- L - Possible Shroud
- M - Probable Tops of Fuel Boxes
- N - Unidentified

REFERENCES

REFERENCES

- 1 ANL-5566 "ALPR Preliminary Design Study Phase I" Mr. Treshow, April 1956
- 2 ANL-6084 "Initial Testing and Operation of The Argonne Low Power Reactor" (ALPR) December 1959
- 3 Quote from "Talk on Pre-Power Zero-Power Reactor Physics Experiments on the ALPR", page 2, D. H. Shaftman (ANL) presented October 11, 1960
- 4 Exhibit I to Modification No. 4 to Contract AT(10-1)-967. Program letter for the period ending September 30, 1960 (page 3) as confirmed by Program letter through September 30, 1961, Modification No. 9
- 5 ABWR Program Proposal, September 26, 1960 (page 5, 3.6 "Manpower Summary")
- 6 ABWR Program for Contract Year, October 1, 1960 through September 30, 1961 (page 3, 3.6 "Manpower Summary")
- 7 AEC, Idaho Operations Office letter of March 13, 1959 from V. V. Hendrix, Director, Division of Military Reactors to W. B. Allred, SL-1 Project Manager, Combustion Engineering
- 8 AEC, Idaho Operations Office letter of March 15, 1959 from V. V. Hendrix, Director, Division of Military Reactors to W. B. Allred, SL-1 Project Manager, Combustion Engineering
- 9 Combustion Engineering letter of May 28, 1959, from W. B. Allred, SL-1 Project Manager to V. V. Hendrix, Director, Division of Military Reactors, Idaho Operations Office, AEC
- 10 ANL-FGF-137, "Bonding of Aluminum with Elemental Silicon", R. A. Noland and D. E. Walker, October 1958
- 11 "Performance of Materials During Six Years Service in The Materials Testing Reactor", A/Conf. 15/p/1878, M. H. Bartz, 1958
- 12 "Effects of Radiation on Materials", Chapter 7, Reinhold, 1958
- 13 ANL-6180, "Irradiation of an Aluminum Alloy-Clad, Aluminum-Uranium Alloy Fueled Plate", July 1960
- 14 H. Kittel (ANL) Telecon of February 1, 1961
- 15 "Principles of Physical Metallurgy", p. 332, M. C. Smith, Harper, 1956
- 16 AERE-M/R-1750, "The Behavior of Fissile Material Under Irradiation at Elevated Temperature", L. M. Wyatt, 1955

REFERENCES (Continued)

- 31 "Analysis of Self-Shutdown Behavior in the SPERT I Reactor"
(AEC Research and Development Report)
IDO-16528 - Reactors-General
TID 4500 (14th Ed.)
- 32 AEC, Idaho Operations Office letter MR:RLM:RD:8 of August 17, 1959
from V. V. Hendrix, Director, Division of Military Reactors to
W. B. Allred, SL-1 Project Manager (CEND)
- 33 Reactor Handbook Engineering, Ch. 1.8, "Transient Generation and
Removal of Heat", pp 150 and 151 by J. P. Silvers and J. R. Dietrich
U. S. Atomic Energy Commission, McGraw-Hill Book Company, Inc. 1955
- 34 Nuclear Science and Engineering, Vol. 6, No. 1, p. 11, "Approximate
Analysis of Reactor Startup Incidents", by M. Hurwits, Jr., July 1959
- 35 CEND letter OP-RO-3119 of April 13, 1961 from W. B. Allred, SL-1 Project
Manager to Dr. C. Wayne Bills, Technical Director, SL-1 Recovery Oper-
ations, AEC
- 36 CEND letter ABWR-ADM-5016 of May 9, 1961 from W. B. Allred, SL-1 Project
Manager to Dr. C. Wayne Bills, Technical Director, SL-1 Recovery Oper-
ations, AEC

APPENDIX

APPENDIX A

SL-1 CONTROL ROD OPERATIONAL HISTORY

Rod No. 1							
Date	Reactor Condition	Rod Operation	Drop Time (sec)	Drop Height (in)	Hang up Location (in)	Type of Sticking	Action Taken
7/26/59	162°F Cold	Rod Withdrawal				I	Retested O.K., 30" drop in .9 secs.
9/4/59	Hot-300 psi	RDT*	2.05	30		I	Retested O.K., 30" drop 1.05 sec. Sept. 9
10/9/59	Hot-300 psi	RDT		20	20	II	Retested O.K. 10" drop in .45 sec.
10/31/59	Hot-300 psi	RDT	6.6	30	17	I	Removed negator spring, retested O.K. 30" drop 1.45 sec.
7/5/60	Hot-300 psi	Scram		18.6	17.8	II	Retested; stuck at 29 from 29.9 drop; removed negator spring Retested; stuck at 1" Retested; stuck at 30". Replaced negator spring and retested O.K. 2 times.
7/11/60	Hot-300 psi	Scram			17	II	Retested O.K. from 10" drop - July 25
8/21/60	112°F Cold	Rod Withdrawal			14.3	III	Retested; stuck at 15" Control rod dis-assembled. Sticking in shroud. Retested again and drops freely from 20"
8/23/60	Cold	RDT Withdrawal			22.4	II	Retested O.K. 20" drop in .85 sec.
9/3/60	Hot-300 psi	1" Rod Exercise		18.2		II	Exercise O.K. at 17.8" 4 Sept; limited to 20" withdrawal Sept. 7
9/11/60	Hot-300 psi	*RDT		10	10	III	Retested O.K. 10" drop in .4 sec. Sept. 13

APPENDIX A (Continued)

Rod No. 3 (Cont)							
Date	Reactor Condition	Rod Operation	Drop Time (Sec)	Drop Height (in)	Hang up Location (in)	Type of Sticking	Action Taken
9/4/59	Hot-300 psi	RDT	2.75	30		I	Retested O.K. from 30" in .96 sec. 9 Sept.
9/12/59	Hot-300 psi	RDT	6.55	27		I	Retested O.K. from 30" in .59 sec. Sept.14
9/14/59	Hot-300 psi	RDT	5.6	30		I	Removed 1 negator spring; retested O.K. from both 25 & 30" Sept.15
10/3/59	Hot-300 psi	Scram	3.0	24		I	Retested O.K. 10" drop in .35 sec. Oct.9
10/30/59	Hot-300 psi	RDT	6.7	30		I	Removed negator spring;retested O.K. from 30" drop in .71 sec.
7/5/60	Hot-300 psi	Scram		18.6	17.8	II	Retested O.K. Dropped from 30" in .71 sec.
7/11/60	Hot-300 psi	Scram		17.6	17	II	Removed negator spring;retested O.K. from 10" drop July 15
8/14/60	Hot-300 psi	Scram	2.8	17.4		I	Retested O.K. 20" drop in .59 sec. 21 Aug.
12/19/60	Hot-300 psi	Individual Rod Scram		25	25	II	Retested,hung up at 3". Retested O.K. dropped from 16" in 1.22 sec.
12/23/60	Hot-300 psi	Individual Rod Scram		19.4	19	II	Plant shut down

Rod No. 5

4/24/59	Hot-300 psi	RDT		17.3	1.8	II	Retest from 10", drop time .8 sec.
---------	-------------	-----	--	------	-----	----	------------------------------------

APPENDIX A (Continued)

Rod No. 5 (cont)							
Date	Reactor Condition	Rod Operation	Drop Time (Sec)	Drop Height (in)	Hang up Location (in)	Type of Sticking	Action Taken
12/17/60	Hot-300 psi	Rod Exercise (Withdrawal)		20	19	III	Clutch assisted by hand. Retested O.K. 30" drop in 1.71 sec. Dec. 20
12/19/60	Hot-300 psi	Rod Withdrawal		20	20-28	III	Clutch assisted using a pipe wrench.
12/19/60	Hot-300 psi	Individual Rod Scram		25	25	II	Retested O.K. dropped from 16" in .52 sec.
12/22/60	Hot-300 psi	Rod Exercise (Full)		30	26.7	II	Dropped clean from approx. 19.5" in .82 sec. on 12/23/60

Rod No. 7							
Date	Reactor Condition	Rod Operation	Drop Time (Sec)	Drop Height (in)	Hang up Location (in)	Type of Sticking	Action Taken
4/24/59	Hot-300 psi	RDT		17.3	2.5	II	Retest from 10", drop time .8 sec.
4/25/59	Hot-300 psi	Scram		19.4	5	II	Retested O.K. April 27
5/1/59	Hot-300 psi	Scram		21.4	21.4	II	Retested. Failed to drop past 25" from 30" drop. Retested O.K. 10" drop in .8 sec. May 4
5/8/59	Hot-300 psi	Scram		21.3	20	II	Retested O.K. 30" drop in 1.5 sec. May 9
5/14/59	Hot-300 psi	Scram		19	14.8	II	Retested O.K. May 15
5/20/59	Hot-300 psi	RDT		30		II	Hung up on all 5 tests Retested 5 times O.K. from 10" .6 sec. drop time - May 21
6/1/59	Hot-300 psi	RDT (Withdrawal)			25.2	III	Could not reach 30" O.K. on full travel June 10.

APPENDIX A (Continued)

Rod No. 7 (Cont)							
Date	Reactor Condition	Rod Operation	Drop Time (sec)	Drop Height (in)	Hang up Location (in)	Type of Sticking	Action Taken
12/7/60	Hot-300 psi	Scram	3.9	19.1		I	Retested O.K. dropped clean from 19.4
12/7/60	Hot-300 psi	Scram		19.4	1	II	Retested O.K. dropped clean from 17"
12/12/60	Hot-300 psi	Scram		19.2	3	II	Retested O.K. dropped clean from 18.8 on Dec. 13.
12/19/60	Hot-300 psi	Individual Rod Scram		25	25	II	Retested O.K. dropped from 16" in .51 sec. Dropped from 30" in 1.71 sec.
12/22/60	Hot-300 psi	Rod Exercise (Full)		19.6	<3	II	Failed to drop from 19.4", 12/23/60
12/23/60	Hot-300 psi	Individual Rod Scram		19.4	19.4	II	Plant Shut down

APPENDIX B
PROCEDURE FOR ZEROING RODS

1. With reactor shutdown and in a cold condition, check to insure that the rods are at their zeroed position as indicated by the control rod position indicators on the control console.
2. Remove the pipe plug from the top of the rod drive housing.
3. Screw in the guide tube in the pipe plug opening until it is completely bottomed. The guide tube contains a slotted hole and a zeroing mark.
4. Insert the measuring rod down through the guide tube until it bottoms on top of the threaded portion of the control rod rack. Check to insure that it is properly bottomed by slipping the lower end of the measuring tube off the top of the rack and bottoming it on upper surface of the scram stop washer (a distance of 1-1/8 inches).
5. In the event the scribe marks of the guide tube and measuring rod do not line up, it is necessary to perform the following using 3 men:
 - a. Disconnect the splined section of the universal coupling from the shaft assembly which supports the negator spring drum. The buffer springs will either raise the rod or the rod will depress the springs depending upon whether the rod was low or high as determined by the difference between scribe marks of the measuring tube and guide tube.
 - b. When the scribe marks are lined up, connect the universal coupling to the shaft assembly. If the spline sections are not rotationally aligned, for engagement, rotate the coupling equivalent to a maximum of $\frac{1}{2}$ of a spline tooth, and in the direction which reduces the small difference that may be present between the scribe marks, and then engage the coupling to the shaft assembly.
 - c. Recheck the zero position with the measuring rod and on the control rod indicators before putting the pipe plug back on the rod drive housing.
6. Install pipe plugs.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

OFFICIAL USE ONLY